

**Deleted**

**11.04.010 California Fire Codes, 2022 Edition – Adopted by reference**

~~Appendix D.~~

Explanation:

Appendix D puts unnecessary design constraints on infrastructure that is generally not operationally necessary and goes beyond the minimum design requirements as set forth in CFC Ch. 5.

**11.04.100 Section 503.2.1 Amended – Dimensions**

~~–Exception: Upon approval of the fire code official, Vertical clearance or road width may be reduced as long as the reduction does not impair access by fire apparatus. In cases where the vertical clearance has been reduced, approved signs shall be installed and maintained indicating the amount of vertical clearance.~~

Explanation

This exception is less restrictive than State code and is therefore unenforceable.